

MONTH	TURBIDITY NTU		TOTAL ALKALINITY mg/L		pH		TOTAL HARDNESS mg/L		CALCIUM HARDNESS mg/L		MAGNESIUM HARDNESS mg/L		CHLORIDES mg/L		SULFATES mg/L		NITRATES mg/L		SODIUM mg/L		TDS mg/L		FLUORIDE mg/L Effluent	TOTAL CHLORINE mg/L System
	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent		
JANUARY	6.0	0.04	70	62	8.34	8.31	70	67	50	49	21	19	0.70	2.80	6.6	24.8	0.11	0.08	7.07	16.0	106	140	0.72	1.76
FEBRUARY	6.3	0.04	67	61	8.38	8.31	69	65	49	48	20	18	0.60	2.70	6.0	22.1	0.10	0.10	6.5	12.0	107	138	0.69	1.72
MARCH	7.4	0.04	67	61	8.17	8.28	71	68	50	50	21	17	0.60	2.60	5.8	21.4	0.12	0.14	5.4	13.6	106	135	0.69	1.67
APRIL	12.1	0.04	66	60	8.22	8.31	69	66	51	50	18	16	0.50	2.80	5.5	22.5	0.10	0.07	5.1	12.7	95	122	0.68	1.64
MAY	7.7	0.03	68	63	8.22	8.31	66	64	50	49	17	15	0.47	3.03	5.4	21.3	0.11	0.12	5.8	13.2	83	107	0.71	1.85
JUNE	8.1	0.03	63	59	8.27	8.38	64	61	46	45	19	16	0.47	3.02	4.6	23.0	0.11	0.10	4.8	30.2	78	107	0.66	1.98
JULY																								
AUGUST																								
SEPTEMBER																								
OCTOBER																								
NOVEMBER																								
DECEMBER																								
<b>Average</b>	<b>7.9</b>	<b>0.04</b>	<b>67</b>	<b>61</b>	<b>8.27</b>	<b>8.32</b>	<b>68</b>	<b>65</b>	<b>49</b>	<b>49</b>	<b>19</b>	<b>17</b>	<b>0.56</b>	<b>2.83</b>	<b>5.65</b>	<b>22.52</b>	<b>0.11</b>	<b>0.10</b>	<b>5.8</b>	<b>16.3</b>	<b>96</b>	<b>125</b>	<b>0.69</b>	<b>1.77</b>

The information presented above is the average monthly value for each measured analyte. Frequency of analysis ranges from continuous monitoring (24/7) to weekly depending on the analyte being measured. In most cases, values are recorded for water entering the facility (influent) and water leaving the facility (effluent).